

GLV 032.024

GOODWE

ET

**C10/26 - DECLARATION OF CONFORMITY for power-generating units
GLV ed2.1.2 (12/2019)**

for the application of annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019)



The undersigned,	Manufacturer: Address:	JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO. No. 90 Zijin Rd., SND Suzhou, CHINA	Represented by: Country: email: Telephone:	JING XIE CHINA jixie.xie@goodwe.com 0086 512 6958 2236
------------------	---------------------------	---	---	---

the following conditions:

1. The power-generating unit complies with the relevant requirements set out in annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019).
2. In order to substantiate this, a separate technical file has been submitted at least for each separate product series of the 'C10/26 list of power-generating units' of this homologation application. Each technical file shall be drawn up on the basis of a checklist Annex D, duly and correctly completed by the manufacturer, accompanied by all the required proof of conformity.
 - 2.1 For technical requirements for which the required proof of conformity (column J in checklist annex D) is a declaration of honour by the manufacturer, the manufacturer declares by signing and dating this declaration of conformity the correctness of the information (conform / not conform / not applicable) provided by him or her in columns K, L and M of this checklist.
 - 2.2. For technical requirements for which the required proof of conformity (column J in checklist Annex D) is a test report or a certificate, the necessary test reports and/or certificates are available * in the technical file:
 - Certificates have been issued by an EN 45011 (or ISO 17065:2012) certification body accredited for these materials.
 - Test reports have been established by an ISO 17025:2005 or ISO 17065:2012 laboratory accredited for these tests.

Done at: Suzhou, China
On: 24-12-2020
(stamp manufacturer & signature)

2020-12-2
4 10:36:45

Homologated by Synergrid on: 04/01/2021
Stamp Synergrid & signature:

SYNERGRID a.s.b.l.-v.z.w.
Galerie Ravensteingalerij 42
BE-1000 Bruxelles/Brussel

* Transition period till 01/05/2020 (see exceptions in chapter 3 of C10/11 ed 2.1 (01/09/2019)) I.V.A./B.T.W : BE 0402.958.091

If at the time of submission of this homologation application it is not yet possible to submit all the necessary certificates and/or test reports (exception 3), or that the units do not yet have all the required characteristics (exceptions 1 and 2), a **temporary homologation** may be granted. All necessary certificates and/or test reports must be in the possession of Synergrid at the latest on 30/04/2020 in order to obtain a final homologation. If this is not the case the temporary homologation will be withdrawn.

C10/26 - homologation - I. GLV
ed2.1.2 (12/2019) on the basis of C10/11 ed.2.1 (01/09/2019)

**FINAL
HOMOLOGATION**

POWER-GENERATING UNITS TO BE HOMOLOGATED FOR LIST C10/26 ACCORDING TO THE REQUIREMENTS OF ANNEX D OF THE TECHNICAL PRESCRIPTION C10/11 ed2.1 (01/09/2019)

2. C10/26 list with power-generating units in accordance with annex D of C10/11 ed2.1 (01/09/2019)

checklist 4.3.2.2 (10/2019)

1	2	3	4	5	6	7	8		9	10	11	12				13	14	15	
							POWER	POWER				ADDITIONAL CHARACTERISTICS	LIMITATIONS	APPLICATION	Synergid approval date				
SYNERGID reference number (GLVxxx-yy-zzzz)	BRAND NAME	Name of the product SERIES	REFERENCE of the model/ type of the unit	FIRMWARE VERSION	power control system type (E1/E2/E3)	Other power control system (central system)	P _{act} rated (active) power (W)	S _{app} maximum apparent power (VA)	1-phase or 3-phase	D.3	D.4.1	D.8.2	D.7.2	D.7.1	D.4.3	D.9.1	(-)	Other	Final homologation
	GOODWE	EH	GW500C-EH	30314 or higher Pave			5000	5000	1-phase	X	X	X	X						Temporary homologation (expires on 01/09/2020)
	GOODWE	EH	GW350C-EH	30314 or higher Pave			3500	3500	1-phase	X	X	X	X						

SRID a.s.b.f.-v.z.w.
 Versteingaterij 4/2
 Las/Brussel
 0402.958.091

FINAL HOMOLOGATION

[Signature]
 2020-12-2
 4 10:37:05